

# 2015 Consumer Confidence Report Data

## PALMYRA WATERWORKS, PWS ID: 12801129

### Water System Information

If you would like to know more about the information contained in this report, please contact Josh Gajewski at (262) 495-4106.

The Village of Palmyra is pleased to provide you with our 2015 Consumer Confidence Report. This report provides information about the quality of the drinking water provided by the Palmyra Water Utility. You will find a brief summary of the groundwater sources and the results obtained from the sampling results for 2015 as well as any violations of Safe Drinking Water Standards. The continued goal of the Water Utility is to provide customers with a safe and dependable supply of drinking water as we have for more than 100 years.

### Opportunity for input on decisions affecting your water quality

Village Board meetings are regularly held the 1st and 3rd Monday of each month beginning at 7 p.m. at the Village Hall - 100 W. Taft St.

### Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

### Source(s) of Water

Source ID	Source	Depth (in feet)	Status
1	Groundwater	172	Active
3	Groundwater	90	Active

To obtain a summary of the source water assessment please contact, Josh Gajewski at (262) 495-4106.

### Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

## Definitions

<b>Term</b>	<b>Definition</b>
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
TCR	Total Coliform Rule
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

## Detected Contaminants

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

### Microbiological Contaminants

Contaminant	MCL	MCLG	Count of Positives	Violation	Typical Source of Contaminant
Coliform (TCR)	presence of coliform bacteria in $\geq 5\%$ of monthly samples	0	1	No	Naturally present in the environment

### Disinfection Byproducts

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2015)	Violation	Typical Source of Contaminant
HAA5 (ppb)	D-6	60	60	1	1		No	By-product of drinking water chlorination
TTHM (ppb)	D-6	80	0	9.2	9.2		No	By-product of drinking water chlorination

### Inorganic Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2015)	Violation	Typical Source of Contaminant
BARIUM (ppm)		2	2	0.045	0.039 - 0.045	9/18/2014	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE (ppm)		4	4	1.3	0.8 - 1.3	9/18/2014	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NICKEL (ppb)		100		1.5000	1.4000 - 1.5000	9/18/2014	No	Nickel occurs naturally in soils, ground water and surface waters and is often used in

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2015)	Violation	Typical Source of Contaminant
								electroplating, stainless steel and alloy products.
NITRATE (N03-N) (ppm)		10	10	3.40	3.40		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
SODIUM (ppm)		n/a	n/a	9.60	8.10 - 9.60	9/18/2014	No	n/a

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2015)	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.1600	0 of 10 results were above the action level.	9/30/2014	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	6.60	0 of 10 results were above the action level.	9/23/2014	No	Corrosion of household plumbing systems; Erosion of natural deposits

### Synthetic Organic Contaminants including Pesticides and Herbicides

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2015)	Violation	Typical Source of Contaminant
DI(2-ETHYLHEXYL) PHTHALATE (ppb)		6	0	1.0	1.0	9/18/2014	No	Discharge from rubber and chemical factories

## Unregulated Contaminants

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. EPA required us to participate in this monitoring.

Contaminant (units)	Level Found	Range	Sample Date (if prior to 2015)
1,2,4-TRIMETHYLBENZENE (ppb)	0.13	0.13	

## Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Palmyra Waterworks is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## Information on Monitoring for Cryptosporidium and Radon

Our water system did not monitor our water for cryptosporidium or radon during 2014. We are not required by State or Federal drinking water regulations to do so.

## Other Compliance

### Monitoring and Reporting Violations

Description	Contaminant Group	Sample Location	Compliance Period Beginning	Compliance Period Ending
Chem M/R - Reg - No Regular samples	Fluoride	Distribution System	7/1/2015	7/31/2015

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the compliance period noted in the above table, we did not complete all monitoring or testing for the contaminant(s) noted, and therefore cannot be sure of the quality of your drinking water during that time.

### Actions Taken

The reason for the violation was due to a lack of submittal of a field collected Fluoride residual sample result by the Palmyra Waterworks for comparative analysis. A checklist system for each required sample has since been implemented to assure compliance in the future.